



Product Service

# CERTIFICATE

No. B 15 05 85127 005

**Holder of Certificate: Wuxi Betteri Electronic Technology Co., LTD**5-1, #11, Jinshan Rd. Branch#IV  
Wuxi Optoelectronic Material  
Science&Technology Park  
214037 Wuxi  
PEOPLE'S REPUBLIC OF CHINA**Production Facility(ies):** 85127**Certification Mark:****Product:** Connector  
Installation Couplers for Use in AC Photovoltaic Systems**Model(s):** BC02-5F65-09(board side)  
BC02-5M65-19(cable side)**Parameters:**  
Rated Voltage: 690VAC  
Rated Current: 50A(10.0mm<sup>2</sup>)  
Overvoltage Category: III  
Application Class: A  
Protection Class: II  
Degree of Protection: IP67  
Rated Impulse Voltage: 6kV  
Poles Configuration: 3P+N+PE**Tested according to:** PPP 59015A:2013

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

**Test report no.:** 704071507101-00**Valid until:** 2020-05-26**Date,** 2015-06-16

Page 1 of 1

  
( Yaqun Liu )