

Certificate of Compliance

Certificate: 2685077

2005077

Project: 2685077

Issued to: Wuxi Betteri Electronic

Technology Co,.Ltd No.11 5-1,JinShan Rd. Branch No.4,Wuxi Optoelectronic Mat Science&Technology Park Wuxi, Jiangsu 214131 China Attention: Zhende Shi Master Contract: 258184

Date Issued:

March 24, 2014

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Rex Yao

Issued by: Rex Yao

PRODUCTS

CLASS 6234 82 - RECEPTACLES-Connectors for Photovoltaic - Systems - Certified to US Standards

CLASS 6234 02 - RECEPTACLES - Connectors for Photovoltaic Systems

PV locking connectors, Model BC03A, BC03B, consisting of male and female connectors, rated 600 V dc, 30 A, suitable for the termination of single, insulated, stranded copper type USE-2 or Photovoltaic Wire (PV Wire) rated 90°C, 105°C, 125°C, or 150°C dry; 90°C wet; 600 Vdc; No. 12 AWG.

APPLICABLE REQUIREMENTS

CSA T.I.L. A-36 - Connectors for Photovoltaic Systems

UL 6703 (Subject) - Connectors For Use in Photovoltaic Systems



Supplement to Certificate of Compliance

Certificate: 2685077

Master Contract: 258184

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
2685077	Mar 24, 2014	PV Connectors.(C/US)