

TUV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD
ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFIKAT



Product Service

CERTIFICATE

No. B 085127 0010 Rev. 00

Holder of Certificate: **Wuxi Betteri Electronic Technology Co., LTD**
5-1, #11, Jinshan Rd. Branch#IV
Wuxi Optoelectronic Material
Science&Technology Park
214037 Wuxi
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Connector**
Installation Couplers for use on AC side of Photovoltaic Systems

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 704071909401-00

Valid until: 2024-03-24

Date, 2019-04-01

(Yaqun Alex Liu)



Product Service

CERTIFICATE

No. B 085127 0010 Rev. 00

Model(s): BC05

Parameters:

Rated Voltage: 300V AC
Rated Current: Male connector: 8A for 16AWG/ 1,5mm²
Female Connector: 30A for 10AWG/6mm²
Overvoltage Category: III
Application Class: A
Protection Class: II
Degree of Protection: IP68(1m, 1h)
Rated Impulse Voltage: 4kV
Poles Configuration: L/N/PE
Temperature Range: -40°C~ + 85°C

Tested according to: PPP 59015A:2013

Production Facility(ies): 085127

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD
ZERTIFIKAT ♦ CERTIFICATE ♦ 認 證 證 書 ♦ CERTIFICADO ♦ CERTIFICAT